



- NOTES:
1. ALL WORK SHALL BE IN ACCORDANCE W/ THE UPC AS ADOPTED BY THE CITY OF SANTA BARBARA
 2. PLUMBING PLAN IS SCHEMATIC ONLY & LICENSED PLUMBING CONTRACTOR SHALL VERIFY ALL SIZES & DESIGN & LAYOUT
 3. FIXTURES SHALL BE AS SELECTED BY OWNER SEE FLOOR PLAN
 4. SAW CUT (E) CONC. SLAB & RE-PATCH AS REQUIRED TO ACCOMMODATE NEW WORK COORDINATE W/ OTHER TRADES TO MINIMIZE SLAB CUTS & WHILE MAINTAINING ALL REQUIRED CLEARANCES COMBINE TRENCHING WERE POSSIBLE
 5. COLD WATER SUPPLY LINES & FITTINGS SHALL BE: TYPE 'L' COPPER; RUN IN ATTIC SPACE
 6. HOT WATER SUPPLY LINE & FITTINGS SHALL BE: TYPE 'L' COPPER; INSULATE RUN IN ATTIC SPACE
 7. SANITARY SEWER LINES SHALL BE: PLASTIC DWV ABS SCHED. 40 SLOPE 1/4" PER FT. MIN. TO DRAIN & CONN. TO (E) SEWER SYSTEM & DR RE-WORK SYSTEM AS REQ.
 8. AT WASHER SPACE: PROVIDE HOT & COLD WATER VALVES & DRAIN LINE.
 9. WHIRLPOOL TUB AS SELECTED BY OWNER COORDINATE & PROVIDE ALL ACCESS PANELS & UNDERSLAB LINES AS REQUIRED
 10. PROVIDE TYPE 'L' COPPER COLD FILTERED WATER SUPPLY LINE TO REF. SPACE
 11. SEWER VENTING SYSTEM: COMBINE & OFFSET AS POSSIBLE IN ATTIC TO BACK / OCEAN SIDE OF RIDGE
 12. GAS LINE: SCHED. 40 BLACK STEEL PIPE W/ BLACK MALLABLE IRON SCEWED FITTINGS RUN IN ATTIC SPACE U.N.D.
 13. ISLAND VENTING SYSTEM WHERE REQUIRED: PROVIDE APPROVED SPECIAL VENTING FOR ISLAND FIXTURES INCLUDING LOOP VENT BELOW DRAINBOARD & FOOT VENT AS REQUIRED
 14. PROVIDE REVERSE OSMOSIS WATER FILTRATION SYSTEM: AS SELECTED BY OWNER LOCATE UNDERSINK AS DIRECTED